



State of Ohio Environmental Protection Agency

Northwe:

OH7057112 FAITH UNITED METHODIST CH-ASHLAND PV 22 11/04/10

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 35  
ww



Re: Richland County  
Faith United Methodist Church-Ashland  
Non-Transient Non-Community  
PWS ID: OH7057112

November 5, 2010

Mr. Rex J. Yarger  
Faith United Methodist Ch-Ashland  
1220 Oswalt Road  
Mansfield, Ohio 44903

**NOTICE OF VIOLATION – ACTION REQUIRED**

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During Fourth Quarter of 2010 (Monthly)**

Faith United Methodist Ch-Ashland is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
10-26-10	Kitchen-Treated	Positive	Negative	Negative	0000003310	877
10-26-10	Mop Sink-Util Room	Positive	Negative	Negative	0000003312	877

**ACTION REQUIRED:**


- Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Mail or other direct delivery to each customer;
  - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;

Mr. Rex J. Yarger  
November 5, 2010  
Page 2

- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). *The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.*
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.
  4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to monitor with five (5) routine samples during November 2010.

If you have any questions, contact this office at 419-373-3105.

Sincerely,



Curtis Eldridge  
Division of Drinking and Ground Waters

//lr

Enclosures: Tier 2 Public Notification (2)  
Public Notice Instructions and Verification Form

pc: Richland County Health Department  
Information Management Section, DDAGW, CO  
DDAGW - NWDO (w/enclosures)