



Re: Richland County
Sacred Heart School
Non-Transient Non-Community Water System
PWS ID#: OH7037812
LEAD / COPPER

April 6, 2011

Ms. Lisa Myers
Sacred Heart School
5754 State Route 61 South
Shelby, Ohio 44875

ACTION REQUIRED

Re: Notice of Violation - Lead and Copper Rule Treatment Technique - Failure to submit Corrosion Control Treatment Recommendation

Dear Ms. Myers:

Your public water system exceeded the **action level for lead** during the June 1 – September 30, 2008, compliance period and was therefore required to perform additional steps to remain in compliance with the lead and copper rules in the Ohio Administrative Code (OAC).

Your system is in violation of the OAC for failure to submit a recommendation or study for Corrosion Control by March 31, 2009. The recommendation submitted on June 4, 2009, to replace the oldest section of the 180 feet of galvanized pipe from the well to the school, is not an approvable option because it does not meet the requirement of the Ohio Administrative Code (OAC) 3745-81-82.

Water Quality parameters require analysis to determine a corrosion control strategy. Attached you will find a list of these parameters. Should you have any questions, please contact Paul Brock at 419.373.3152 or email: paul.brock@epa.state.oh.us.

Actions required as a result of the above violation(s):

- 1. Complete a revised recommendation and submit it to this office immediately.** If significant changes to your water system are needed to implement the Corrosion Control Recommendation, detail plans for those changes are also necessary and should be submitted along with the Recommendation. The detail plans must be prepared and signed by an engineer with a professional engineer's (P.E.) license.

Ms. Lisa Myers
April 6, 2011
Page 2

2. **Issue public notification:** Within 30 days of the date of this letter, issue public notification as required by OAC rule 3745-81-32. An example public notification is enclosed.
3. Within **10 days** of completing Steps 1 and 2, fill out the attached verification form and send it, along with a copy of the public notification issued, to this District Office.

If you have any questions concerning the requirements in this letter or need to request technical assistance, please feel free to contact me at 419-373-3152.

Sincerely,



Paul G. Brock, P.E.
Engineering Supervisor
Division of Drinking and Ground Waters

/lr

Enclosure: Public Notice
Verification Form for Public Notice

pc: Richland County Health Department
Toni Buchanan, DDAGW-CO
DDAGW, NWDO File

ec: Curt Eldridge, DDAGW, NWDO
Musa Khaleq P.E. DDAGW, NWDO