




Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH7037812 SACRED HEART SCHOOL

59 04/06/11



Re: Richland County  
Sacred Heart School  
Non-Transient Non-Community Water System  
PWS ID#: OH7037812  
**LEAD / COPPER**

April 6, 2011

Ms. Lisa Myers  
Sacred Heart School  
5754 State Route 61 South  
Shelby, Ohio 44875

**ACTION REQUIRED**

Re: **Notice of Violation - Lead and Copper Rule Treatment Technique - Failure to monitor for and report some or all Water Quality Parameters**

Dear Ms. Myers:

Your public water system exceeded the **action level for lead** during the June 1- September 30, 2008, compliance period and was therefore required to perform additional steps to remain in compliance with the lead and copper rules in the Ohio Administrative Code (OAC).

Your system is in violation of the OAC for failure to monitor for and report Water Quality Parameters by February 10, 2009.

**Actions required as a result of the above violation(s):**

1. **Monitor for and report Water Quality Parameters, according to the attached instructions (*Water Quality Parameter and Lead & Copper Monitoring*), immediately.**
2. **Issue public notification:** Within 30 days of the date of this letter, issue public notification as required by OAC rule 3745-81-32. An example public notification is enclosed.
3. Within **10 days** of completing Steps 1 and 2, fill out the attached verification form and send it, along with a copy of the public notification issued, to this District Office.


Northwest District Office  
347 North Dunbridge Road  
Bowling Green, OH 43402-9398

419 | 352 8461  
419 | 352 8468 (fax)  
www.epa.ohio.gov

Ms. Lisa Myers  
April 6, 2011  
Page 2

If you have any questions concerning the requirements in this letter or need to request technical assistance, please feel free to contact me at 419-373-3152.

Sincerely,



Paul G. Brock, P.E.  
Engineering Supervisor  
Division of Drinking and Ground Waters

/llr

Enclosures: Water Quality Parameter and Lead & Copper Monitoring  
Form 5108  
Public Notice  
Verification Form for Public Notice

pc: Richland County Health Department  
Toni Buchanan, DDAGW-CO  
~~DDAGW-NWDO File~~

ec: Curt Eldridge, DDAGW-NWDO  
Musa Khaleq P.E., DDAGW-NWDO