



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH7035012

ST MARYS CHURCH AND SCHOOL

5/27/2011



Re: Richland County  
St. Mary's Church and School  
NT Non-Community Water System  
PWS ID# OH7035012

May 27, 2011

Mr. Chuck Cooney  
St. Mary's Church and School  
1630 Ashland Road  
Mansfield, Ohio 44905

Dear Mr. Cooney:

Ohio Administrative Code (OAC) Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual measured at representative points throughout the distribution system.

Review of your January 2011 operational reports indicate that free chlorine residuals were below this level a total of 3 days.

Review of your February 2011 operational reports indicate that free chlorine residuals were below this level a total of 13 days.

Review of your March 2011 operational reports indicate that free chlorine residuals were below this level a total of 5 days.

An investigation needs to be made to find the cause of these low chlorine residuals and steps need to be taken to bring the water system back to compliance with OAC Rule 3745-83-01.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our Web site at <http://www.epa.ohio.gov>. If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via email at [curt.eldridge@epa.state.oh.us](mailto:curt.eldridge@epa.state.oh.us).

Yours truly,

Curtis A. Eldridge  
Environmental Specialist 2  
Division of Drinking and Ground Water

/cs

pc: Richland County Health Department  
DDAGW/NWDO File