



State of C

OH7237112

LUTZ ELEMENTARY SCHOOL

5/2/2007

No

TE

347 North Dunbridge Road
Bowling Green, OH 43402-9398



governor
governor
Director

Re: Sandusky County
Lutz Elementary School
Nontransient Noncommunity Public Water
System
PWS ID#OH7237112

May 2, 2007

Steve Goetz
Supervisor of Buildings and Grounds
Fremont City Schools
1220 Cedar Street
Fremont, Ohio 43420

Dear Mr. Goetz:

After review of the March 2007 Plant-Distribution Monthly Operation Report, submitted in accordance with Ohio Administrative Code (OAC) Rule 3745-81-01 (copy enclosed), I offer the following comments for your consideration.

The reported concentration levels of free and combined chlorine residuals, maintained for the purpose of disinfection, are significantly below that recommended for noncommunity public water systems and required if serving a population of at least one thousand people. I recommend you review the purpose, desired concentration, and operation of the chemical feed of sodium hypochlorite.

The report was incomplete:

1. Columns were not summarized to report total, maximum, minimum, and average values. Future Plant-Distribution Monthly Operation Reports shall include this information.
2. Information on daily water system pumpage (plant production measured in gallons per day) was not reported. By June 1, 2007, a plan of proposed action shall be submitted to Musa Khaleq, District Engineer, as to the method and equipment to be used to measure daily water system pumpage. Reporting shall be required to begin with the operation report for the month of September, 2007.

Mr. Steve Goetz
May 2, 2007
Page Two

The operation report and Total Chlorine Residual Quarterly Operating Report shall be signed by the operator in responsible charge designated in accordance with OAC rule 3745-7-02 and submitted to the district office no later than the tenth of the month following the month for which the report was prepared. The March 2007 operation report was received April 25, 2007 and signed by Martha Frater.

Questions, please contact me at 419-373-3042.

Sincerely,



Larry Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters

/lb

pc: ~~DDAGW/NWDO~~

ec: Linda Benham, Supervisor, DDAGW/NWDO
Lisa Jones-Gast, Supervisor, DDAGW/NWDO
Ellen Gerber, Manager, DDAGW/NWDO
Musa Khaleq, District Engineer, DDAGW/NWDDO