



State of Ohio Environmental Protection Agency

OH7448712

SOUTHERN REGION INDUSTRIAL REALTY, INC

7/2/2008

Northwest



\* 0 H 7 4 4 8 7 1 2 7 2 2 0 0 8 N O V \*

OHIO ENVIRONMENTAL PROTECTION AGENCY

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419

RE: Seneca County  
Caliber Auto Transfer of Ohio, Inc.  
Non-Transient Non-Community System  
PWS ID. #: 7448712

July 2, 2008

Mr. Thomas Huffman, Manager  
Caliber Auto Transfer of Ohio, Inc.  
3101 N. Twp. Rd. 47  
Fostoria, Ohio 44830

Dear Mr. Huffman:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for your public water system for the month of May 2008.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) and iron must be monitored monthly at a state certified lab according to OAC Rule 3745-83-01(G). Ohio Administrative Code (OAC), Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The June monthly operational report should be submitted to the district office no later than July 10<sup>th</sup>].

**The owner / operator of Caliber Auto Transfer of Ohio is in violation of OAC Rule 3745-83-01(G), OAC Rule 3745-83-01(I) for not completing the above requirements.**

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/csi

pc: Toni Buchanan, IMS, DDAGW, CO  
Emily Cushman, DDAGW, CO  
Mike Moffett, Caliber Auto Transfer  
Seneca County Health Department  
DDAGW, NWDO File