



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Seneca County
Caliber Auto Transfer of Ohio, Inc.
Non-Transient Non-Community System
PWS ID. #: 7448712

February 28, 2008

OH7448712

FOSTORIA MIXING CENTER

2/28/2008

Mr. Thomas Huffman, Manager
Caliber Auto Transfer of Ohio, Inc.
3101 N. Township Road 47
Fostoria, Ohio 44830



Dear Mr. Huffman:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for the month of January 2008.

However, Ohio Administrative Code (OAC) Rule 3745-83-01(G)(9) requires that iron must be monitored monthly at a state certified lab for a system that treats the water for iron and has a population of 250 or less.

The owner / operator of Caliber Auto Transfer of Ohio, Inc. is in violation of OAC Rule 3745-83-01(G)(9) for not completing monthly iron monitoring.

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Toni Buchanan, IMS, DDAGW, CO
Mike Moffett, Caliber Auto Transfer
Seneca County Health Department
DDAGW, NWDO File