



State of Ohio E

OH7448712


SOUTHERN REGION INDUSTRIAL REALTY, INC

1/22/2008

Northv

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419)



* 0 H 7 4 4 8 7 1 2 1 2 2 2 0 0 8 N O V *

or
or
or

RE: Seneca County
Caliber Auto Transfer of Ohio, Inc.
Non-Transient Non-Community System
PWS ID. #: 7448712

January 22, 2008

Mr. Thomas Huffman, Manager
Caliber Auto Transfer of Ohio, Inc.
3101 N. Twp. Rd. 47
Fostoria, Ohio 44830

Dear Mr. Huffman:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for the months of October, November, and December 2007.

However, Ohio Administrative Code (OAC) Rule 3745083-01(G)(9) requires that iron must be monitored monthly at a state certified lab for a system that treats the water for iron and has a population of 250 or less.

In addition, the Ohio EPA, Total Chlorine Residual Quarterly Operating Report (EPA 5114) (QOR) has not been received for the calendar quarter of October to December 2007.

Disinfection residual measurements are required to be taken for **total** chlorine according to Ohio Administrative Code (OAC) Rules 3745-81-70 (E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10th of the month following the end of the calendar quarter being reported. [e.g., The fourth calendar quarter (October - December) should be submitted to the district office no later than January 10th.]

The owner / operator of Caliber Auto Transfer of Ohio, Inc. is in violation of OAC Rule 3745-83-01(G)(9) for not completing monthly iron monitoring and OAC Rule 3745-81-70(E) for not completing or submitting a quarterly operating report.

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters
/cs)

pc: Toni Buchanan, IMS, DDAGW, CO
Mike Moffett, Caliber Auto Transfer

Seneca County Health Dept.
DDAGW, NWDO File