



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Seneca County
Caliber Auto Transfer of Ohio, Inc.
Non-Transient Non-Community System
PWS ID. #: 7448712

August 31, 2007

Mr. Thomas Huffman, Manager
Caliber Auto Transfer of Ohio, Inc.
3101 N. Twp. Rd. 47
Fostoria, Ohio 44830

OH7448712 SOUTHERN REGION INDUSTRIAL REALTY, INC 8/31/2007



Dear Mr. Huffman:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for your public water system for the month of July 2007.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) and iron must be monitored monthly at a state certified lab according to OAC Rule 3745-83-01(G). Ohio Administrative Code (OAC), Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The July monthly operational report should be submitted to the district office no later than August 10th].

The owner / operator of Caliber Auto Transfer of Ohio, Inc. is in violation of OAC Rule 3745-83-01(G) and OAC Rule 3745-83-01(I).

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/lb

pc: Kevin Hosler, Caliber Auto Transfer
Seneca County Health Department

~~DDAGW, NWDO File, Caliber Automotive~~