



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Seneca County  
Caliber Auto Transfer of Ohio, Inc.  
Non-Transient Non-Community System  
PWS ID. #: 7448712

March 27, 2007

OH7448712 SOUTHERN REGION INDUSTRIAL REALTY, INC 3/27/2007

Mr. Thomas Huffman, Manager  
Caliber Auto Transfer of Ohio, Inc.  
3101 N. Township Road 47  
Fostoria, Ohio 44830



Dear Mr. Huffman:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for your public water system for the month of February 2007.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) and iron must be monitored monthly at a state certified lab according to OAC Rule 3745-83-01(G). Ohio Administrative Code (OAC), Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., February's monthly operational report should be submitted to the district office no later than March 10<sup>th</sup>].

In accordance with OAC Rule 3745-83-01 plant production or gallons per day produced by the water treatment plant shall be recorded daily and reported on EPA 5002. If your plant does not have a water meter, a water meter shall be installed in consultation with Ralph Baker, District Engineer (419-373-3048).

**The owner / operator of Caliber Auto Transfer of Ohio, Inc. is in violation of OAC Rule 3745-83-01(G) and OAC Rule 3745-83-01(I).** If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

//lr

pc: Kevin Hosler, Caliber Auto Transfer  
Seneca County Health Department  
~~DDAGW;NWDO~~ File