

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us


Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director

RE: Seneca County
Caliber Auto Transfer of Ohio, Inc.
Non-Transient Non-Community System
PWS ID. #: 7448712

January 3, 2007

Mr. Thomas Huffman, Manager
Caliber Auto Transfer of Ohio, Inc.
3101 N. Twp. Rd. 47
Fostoria, Ohio 44830

DH7448712 SOUTHERN REGION INDUSTRIAL REALTY, INC 1/3/2007



Dear Mr. Huffman:


The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for your public water system for the month of November 2006.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) and iron must be monitored monthly at a state certified lab according to OAC Rule 3745-83-01(G). Ohio Administrative Code (OAC) Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., December's monthly operational report should be submitted to the district office no later than January 10th].

The owner / operator of Caliber Auto Transfer of Ohio, Inc. is in violation of OAC Rule 3745-83-01(G) and OAC Rule 3745-83-01(I). The aforementioned report must be submitted monthly (EPA 5002) with all required sampling information.

Please submit any reports that have been previously completed or provide an explanation as to why the reports were not completed. If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,



Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/csl

pc: Kevin Hosler, Caliber Auto Transfer
Toni Buchanan, IMS, DDAGW, CO
Seneca County Health Department
DDAGW, NWDO File