



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH8741612

PRINCIPLE BUSINESS ENTERPRISES

10/1/2010



Re: Wood County
Principle Business Enterprises PWS
NTNC Public Water System
PWS ID# OH8741612
LEAD / COPPER

ACTION REQUIRED

October 1, 2010

Mr. Charles A. Stocking, President
Principle Business Enterprises Inc.
P. O. Box 129
Dunbridge, Ohio 43414

Dear Mr. Stocking:

Principle Business Enterprises public water system exceeded the lead action level during the 2004 – 2006 triennial compliance period (June 1 – September 30, 2006, monitoring period) and was, therefore, required to perform additional steps to remain in compliance with the lead and copper rules in the Ohio Administrative Code (OAC) Rule 3745-81-81 and 82.

Principle Business Enterprises Inc. is in violation of the OAC Rule 3745-81-82 for failure to submit a Corrosion Control Recommendation by March 31, 2007. EPA Form 141C as well as the water quality parameters are enclosed for your use. Submit EPA Form 141C to my attention by October 15, 2010, to avoid potential enforcement action as the result of your ongoing non-compliance with Ohio public drinking water regulations.

If you have any questions regarding this letter, please contact Linda Benham at 419-373-4117 or Jill Schiefer at 419-373-3089.

Sincerely,

Ellen J. Gerber
Manager
Division of Drinking and Ground Waters

LSB/cs

pc: Joe Matthews, Project Manager
Wood County Health Department
DBAGW;-NWDO-File