





**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**

Re: Paulding County
Brentwood Community MHP LLC
Community Water System
PWS ID# OH6300212

September 27, 2012

Mr. Tim Smith
Brentwood Community MHP LLC
103 A Degroff Avenue
P. O. Box 218
Archbold, Ohio 43502

Dear Mr. Smith:

This office inadvertently provided a notice of violation for failing to comply with the operational requirements of Ohio Administrative Code (OAC) 3745-83-01 during the month of August 2012.

The notice stated that in violation of 3745-83-01 (C) (1), the public water system failed to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system. Our notice of violation for August 2012 is hereby rescinded.

If you have any questions, please contact this office.

Sincerely,

Chris Riddle
Division of Drinking and Ground Waters

/lr

pc: Thomas Roth, Operator
Paulding County Health Department
DDAGW, NWDO File

