



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Allen County
Allen East High School
Allen East Middle School
Non-Transient Non-Community System
PWS ID# 0251712
PWS ID # 0235412

212

February 21, 2007

OH0235412

ALLEN EAST COMMUNITY CENTER

2/21/2007

Superintendent
Allen East Local Schools
9520 Harrod Road
Harrod, Ohio 45850



Dear Superintendent:

The Ohio EPA, Division of Drinking and Ground Waters (DDAGW), Water Plant – Distribution Monthly Operating Report (EPA 5002) (MOR) has not been received for the month of January 2007 for Allen East High School and Allen East Middle School.

Ohio Administrative Code (OAC) Rule 3745-83-01, specifies operational requirements for Non-Transient Non-Community Water Systems like the aforementioned schools. The MOR requirements for each school are specified below:

- Allen East High School – Daily Plant Production and Daily free and combined chlorine residual at the plant tap and in the distribution.
- Allen East Middle School - Daily Plant Production and weekly hardness by a certified laboratory

In addition to the MOR requirements specified above bromate needs to be sampled and reported monthly for the High School.

Allen East Local School is in violation of OAC Rule 3745-83-01 for not submitting a monthly operating report for January 2007 containing the required operational analyses.

Superintendent]
February 23, 2007
Page Two

If you have any questions as a result of this letter, then please contact me at (419) 373-3101.

Sincerely,

Ben Smith

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/lb

pc: Toni Buchanan, IMS, DDAGW, CO
Allen County Health Department
DDAGW, Allen East High School NWDO File
~~DDAGW, Allen East Middle School NWDO File~~