



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director


Re: Allen County
Biggies Coast to Coast
TNC Water System
PWS ID #0232012

February 22, 2007

OH0232012 BIGGIES COAST TO COAST

24 02/22/07

Mr. Bryan L. Best
Biggie's Coast to Coast
2250 East Lincoln Highway
Elida, Ohio 45807



Dear Mr. Best:

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

- Monitoring Period:** January 2007
- Required Coliform Sampling:** Five samples in the month after a coliform-positive
- Sample Results Submitted:** Four samples collected on January 31, 2007

Actions required as a result of the above violation:	
Step 1	<p>Within 30 days issue public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> 1. continuous posting, mail, or other direct delivery; and 2. if necessary, the system must also use any other method reasonably calculated to reach all persons.
Step 2	<p>Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.</p>

Mr. Bryan L. Best
February 22, 2007
Page 2

If you have any questions, please contact me at (419) 373-3101.

Sincerely,



Ben Smith
Division of Drinking and Ground Waters

/lr

Enclosures

pc: Toni Buchanan, DDAGW, CO
Allen County Health Department
DDAGW, NWDO File. ↗