



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Allen County
Congregational Christian Church
TNon-Community Water System
PWS ID #0233312

February 16, 2007

OH0233312 LAFAYETTE CONGREGATIONAL CHRISTIAN C 22 02/16/07

Congregation
Congregational Christian Church
201 West Main Street
P.O. Box 7004
Lafayette, Ohio 45854



Dear Congregation:

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Your public water system incurred a **monthly** violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in February 2007.


A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.

Sample Date	Sample Tap	Total Coliform	Fecal Coliform	<i>E. coli</i>	Sample Number	Lab Cert. Number
02-06-07	Kitchen Sink	Positive	--	Negative	2070700 1	840
02-06-07	Kitchen Sink	Positive	--	Negative	2070700 2	840
02-06-07	Kitchen Sink	Positive	--	Negative	2070700 3	840
02-06-07	Kitchen Sink	Positive	--	Negative	2070700 4	840

Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue the enclosed public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.).</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in March 2007.

If you have any questions, please contact me at (419) 373-3101.

Sincerely,



Ben Smith
Division of Drinking and Ground Waters

/l/r

Enclosures

pc: Toni Buchanan, DDAGW, CO
Allen County Health Department
cDDAGW-NWDO File