Ohio | Environmental Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH0252912 MARATHON MINI MART 22 11/16/10

OH0252912724710 6

Re: Allen County
Marathon Mini Mart
Transient Non-Community
PWS ID: OH0252912

November 17, 2010

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Javed Iqbal
Marathon Mini Mart
6459 Bellefontaine Road
Lima, Ohio 45804

Subject: Violation of Total Coliform Maximum Contaminant Level (MCL) During Fourth Quarter 2010 (Monthly)

Marathon Mini Mart is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Repeat samples taken pursuant to OAC 3745-81-21(B). . . .*shall be used to determine compliance with the maximum* contaminant level for total coliforms as set forth in OAC, Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present. The following samples determine the Fourth Quarter 2010 Monthly MCL violation:

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
10-28-10	Employee RR Sink	Positive	Negative	Negative	0000021468	877
11-11-10	Employee RR Sink	Positive	Negative	Negative	0000016237	877
11-11-10	Employee RR Sink	Positive	Negative	Negative	0000016238	877
11-11-10	Employee RR Sink	Positive	Negative	Negative	0000016239	877
11-11-10	Employee RR Sink	Positive	Negative	Negative	0000016240	877

ACTION REQUIRED:

1. **Investigate and eliminate the cause of bacterial contamination**. Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").

2. **Notify the people served by this water system**. Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served. The appropriate methods for your system are listed below under the **Transient Non-Community** column.

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov

Community	Transient or Non Transient Non-Community
• Mail or other direct delivery to each customer • If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting	• Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas; • Mail or other direct delivery to each customer • Send to parents or guardians of children at schools or day care facilities • E-mail, newsletters or newspaper
Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.	

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Northwest District Office. Include a copy of each notice distributed, published or posted.

4. **Monitor with at least five (5) routine samples** in the month following a routine total *coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to* monitor with five (5) routine samples during the month of November 2010.

If you have any questions, contact this office at 419-373-3042.

Sincerely,

Larry W. Moritz

Larry W. Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters

/llr

Enclosures: Tier 2 Public Notification (2)
Public Notice Instructions and Verification Form

pc: Allen County Health Department
DDAGW – NWDO (w/enclosures)
Information Management Section, DDAGW, CO

P[illegible]T THIS FORM

DRINKING WATER NOTICE

Tests show coliform bacteria in Marathon Mini Mart's water

Marathon Mini Mart is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Repeat samples taken pursuant to OAC 3745-81-21(B). . . .shall be used to determine compliance with the maximum contaminant level for total coliforms as set forth in OAC, Rule 3745-81-14. A routine sample was collected October 28, 2010, and four (4) repeat samples were collected November 11, 2010. All of these samples were Total Coliform Positive.

What should I do?

- *You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.*

- *Total coliform bacteria are generally not harmful themselves. Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution system.*

- *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. Fecal coliform or E. coli, which are bacteria of greater concern, were not detected in the water.*

What is being done?

We are still detecting coliform bacteria. We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact _____ at _____
name of contact phone number

or at _____.
mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID# OH0252912	Date Distributed:

Tier 2: Unresolved Total Coliform Monthly MCL Notice

COMPLETE THIS FORM ALONG WITH THE VERIFICATION FORM AND SEND THEM BOTH BACK TO OHIO EPA

DRINKING WATER NOTICE

Tests show coliform bacteria in Marathon Mini Mart's water

Marathon Mini Mart is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Repeat samples taken pursuant to OAC 3745-81-21(B). . . .shall be used to determine compliance with the maximum contaminant level for total coliforms as set forth in OAC, Rule 3745-81-14. A routine sample was collected October 28, 2010, and four (4) repeat samples were collected November 11, 2010. All of these samples were Total Coliform Positive.

What should I do?

- *You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.*

- *Total coliform bacteria are generally not harmful themselves. Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution system.*

- *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. Fecal coliform or E. coli, which are bacteria of greater concern, were not detected in the water.*

What is being done?

We are still detecting coliform bacteria. We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact _____ at _____
name of contact phone number

or at _____.
mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID# OH0252912	Date Distributed:

Tier 2: Unresolved Total Coliform Monthly MCL Notice

PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR NON-COMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS

The owner or operator of a non-community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
Use one or more of the following methods to reach all persons served by the public water system: 1. Public notice issued by posting in conspicuous locations throughout the distribution system (required to remain posted for as long as the violation exists, but in no case less than 7 days 2. Public notice issued by mail or other direct delivery to each customer and service connection (where known).	**Describe actual methods used to notify public of the violation:** 1A. Dates of posting _____ 1B. Locations of posting _____ _____ _____ 2. Date of mailing/delivery _____
Schools and Day-Care Facilities must notify parents or guardians of children being served by methods besides posting, such as a newsletter, e-mail notice, or direct mailing	A. Method(s) _____ _____ B. Date(s) _____
If the above methods do not reach all persons served, also use any other method reasonably calculated to reach other persons served by the system (e.g. publication in a local newspaper or newsletter, use of e-mail to notify employees or students, or delivery of multiple copies to central locations).	A. Method(s) _____ _____ _____ B. Date(s) _____

Complete the enclosed verification form and mail it to Ohio EPA - Northwest District Office.
INCLUDE A COPY OF THE PUBLIC NOTICE.

_____
Signature of Responsible Person Date

_____
Printed Name and Title of Responsible Person

Marathon Mini Mart
OH0252912
Allen County
Fourth Quarter of 2010
Total Coliform Monthly MCL (Vio. Type 22)

For Ohio EPA use only:
Date PN received: _____
PN acceptable: _____ **PN not acceptable:** _____