



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH0247812

ODOT REST AREA 1-31 EB

3/17/2011



Re: Allen County
ODOT Rest Area 1-31 EB
TNC Water System
PWS ID# 0247812
STU ID# 252686

March 17, 2011

Mr. Kirk Slusher, District Deputy Director
ODOT- District 1
1885 North McCullough Street
Lima, Ohio 45802

RE: Notice of Violation – Monthly Report

Dear Mr. Slusher:

The February 2011 Plant – Distribution Monthly Operation Report (EPA Form 5002) was received by the Ohio EPA-Northwest District Office on March 10, 2011.

OAC Rule 3745-83-01(C)(1) requires a system which adds chlorine to maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system. A review of February 2011 shows 3 days during the month a chlorine residual was not being maintained in the distribution system. Take steps to immediately correct this problem.

ODOT Rest Area 1-31 EB does not need to monitor for pH and Stability.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Allen County Health Department
DDAGW, NWDO File