



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Allen County
Sandy Point Lake
TNC Water System
PWS ID # OH0239412


October 10, 2007

OH0239412

SANDY POINT LAKE

10/10/2007

Stan & Kathi Gasser, Owners
Sandy Point Lake
720 North Water Street
Fort Jennings, Ohio 45844



Dear Mr. & Mrs. Gasser:

This letter will confirm removal of the water use advisory required in our letter dated September 26, 2007. This is based on one set of four total coliform negative (safe) samples collected October 3, 2007.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by October 23, 2007.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of October 2007.

Yours truly,

Ben Smith
Division of Drinking and Ground Waters

JKS/lb

pc: Allen County Health Department
Data Management Section, DDAGW, CO, Attn: Toni Buchanan
~~BBAGW, NWDO~~