



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Ashland County
Hickory Lakes Campground
TNon-Community Water System
PWS ID# OH0337012

September 24, 2007

Mr. Randy Burkhead
Hickory Lakes Campground
23 Township Road 1300
West Salem, Ohio 44287

OH0337012 HICKORY LAKE CAMPGROUND B-AREA 22 09/24/07



Dear Mr. Burkhead:

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Your public water system incurred a **monthly** violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in September 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.

Sample Date	Sample Tap	Total Coliform	Fecal Coliform	E. coli	Sample Number	Lab Cert. Number
09-18-07	B - Well	Positive	--	Negative	30293	110
09-20-07	B - Well	Positive	--	Negative	30329	110

Actions required as a result of the above violation	
Step 1	Within 30 days issue the enclosed public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.).
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in October 2007.

Mr. Randy Burkhead
September 24, 2007
Page 2

If you have any questions, please contact me at (419)373-3102.

Sincerely,

Dean A. Twining /jbs

Dean A. Twining
Division of Drinking and Ground Waters

/csl

Enclosures

pc: Toni Buchanan, DDAGW, CO
Ashland County Health Department
DDAGW-NWDO File