



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Ashland County
Quaker Springs Restaurant
TNC Water System
PWS ID # 0340712

July 20, 2007

OH0340712

QUAKER SPRINGS RESTAURANT

7/20/2007

Mr. Roger Gaines
Quaker Springs Restaurant
1060 State Route 95
Perrysville, Ohio 44864



Dear Mr. Gaines:

This letter will confirm removal of the water use advisory required in our letter dated July 12, 2007. This is based on one set of four total coliform negative (safe) samples collected on July 18, 2007.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, Ohio 43402, by August 3, 2007.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of July 2007.

Yours truly,

Dean A. Twining
Dean A. Twining
Division of Drinking and Ground Waters

/lr

pc: Ashland County Health Department
Data Management Section, DDAGW, CO, Attn: Toni Buchanan
☞DDAGW;NWDO☜