



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Auglaize County
Church of Christ of Auglaize County
TNC Public Water System
PWS ID# OH0637412

September 28, 2007

OH0637412 CHURCH OF CHRIST OF AUGLAIZE COUNTY | 25 09/28/07

Certified Mail



Mr. Marion Miller
Church of Christ of Auglaize County
15257 Blank Pike Road
P.O. Box 1714
Wapakoneta, Ohio 45895

Dear Mr. Miller:

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (Acute & Failure to Monitor with four repeat samples)

During September 2007, your public water system incurred an **acute** violation of Rule 3745-81-14(D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of Rule 3745-81-21(B)(1) of the OAC for failure to collect a total of four (4) repeat samples within the required time period.

Our records indicate that a total coliform-positive sample was collected from this water system on September 11, 2007, and that either no repeat samples were collected or only some repeat samples were collected.

Actions required as a result of the above violations:

1. **Within 24 hours**, consult with Ohio EPA and use the following methods to reach all persons served by the public water system, in accordance with Rule 3745-81-32 of the OAC:
 - A. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.).
2. Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
3. Fill out the enclosed verification form and send it along with a copy of the public notification issued to the Northwest District Office of Ohio EPA.

Mr. Marion Miller
September 28, 2007
Page Two

4. The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample."
5. You are required to monitor with at least five (5) samples in the next month following any total coliform-positive result. You must take at least five (5) total coliform samples in October 2007.

If you have any questions, please contact me at (419) 373-3042.

Sincerely,



Larry Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters

JKS/lb

Enclosures

pc: Toni Buchanan, DDAGW, CO
Auglaize County Health Department
~~DDAGW;NWDG;File~~