



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Auglaize County  
Community Family Health Center  
TNC Water System  
PWS ID# OH3332412

December 24, 2007

Dr. Greg Bergman, President  
Community Family Health Center, Inc.  
04463 State Route 66 North  
P. O. Box 2  
Minster, Ohio 45865

OH0636412

MIAMI & ERIE MEDICAL CENTER PWS

12/24/2007



Dear Dr. Bergman:

**Subject: NOV for Failure to Respond to Significant Deficiencies**

This letter is notification that the Community Family Health Center is in violation of Ohio Administrative Code (OAC) Rule 3745-81-60(D) for failure to respond in writing within 45 days indicating how and on what schedule the system will address the requirements listed in my correspondence dated November 6, 2007. The last survey of the Community Family Health Center's water system was performed on October 19, 2007, and the following was identified as a corrective action needing to be addressed:

1. Our files do not show an ion-exchange softener being part of the drinking water system in the past. It was my understanding during the survey that the ion-exchange softener is part of the heating and cooling system. Verify this information in writing to our office.

**The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.**

If you have any questions regarding this letter, please feel free to contact me at (419)373-3089 or via email at [jill.schiefer@epa.state.oh.us](mailto:jill.schiefer@epa.state.oh.us). Questions regarding any other matters concerning your water system should be directed to Larry Moritz at (419)373-3042 or via email at [larry.moritz@epa.state.oh.us](mailto:larry.moritz@epa.state.oh.us).

Sincerely,

Jill A. Schiefer  
Environmental Specialist II  
Division of Drinking and Ground Waters

/cs

pc: Auglaize County Health Department  
Dave Evans, DDAGW, CO  
~~DDAGW=NWDO:file~~  
ec: Linda Benham, DDAGW, NWDO  
Larry Moritz, DDAGW, NWDO