



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Auglaize County  
Dad's Drive-In  
TNC Water System  
PWS ID# 0637612

October 30, 2007

Ms. Donna Wyatt, Owner  
Dad's Drive-In  
701 Stoney Brook Drive  
St. Marys, Ohio 45885

OH0637612 DADS DRIVE-IN PWS

23 10/30/07



**Subject: Notice of Violation - Failure to Sample Drinking water as Required for Total Coliforms**

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

**Monitoring Period:** July - September 2007  
**Required Coliform Sampling:** One sample per quarter  
**Sample Results Submitted:** None

Actions required as a result of the above violation:	
Step 1	Within 30 days issue public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods:  1. continuous posting, mail, or other direct delivery; and  2. if necessary, the system must also use any other method reasonably calculated to reach all persons.
Step 2	Within ten (10) days of completing <b>Step 1</b> above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.

If you have any questions, please contact me at (419) 373-3042.

Sincerely,

Larry Moritz, R.S., M.S.I.H.  
Division of Drinking and Ground Waters

/cs

Enclosures

pc: Toni Buchanan, DDAGW, CO  
Auglaize County Health Department  
DDAGW, NWDO File