




Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH0632412

ODOT REST AREA 7-26

11/1/2011



Re: Auglaize County
ODOT Rest Area 7-26 PWS
NTNC Public Water System
PWS ID# 0632412

November 1, 2011

Mr. Lonnie Falknor
1001 St. Marys Avenue
P. O. Box 969
Sidney, Ohio 45365

Notice of Violation – Monthly Report – Chlorine Residual Distribution

Dear Mr. Falknor:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system September 10, 11, 17, 22, 23, 24, 25, 26, and 27.

OAC Rule 3745-83-01 (C) (1) requires all noncommunity public water systems serving at least 1,000 people to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Notice of Deficiency

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l on September 10, 13, 17, 22, 23, 24, 25, 26, and 27.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,

Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/lir

pc: Auglaize County Health Department
BDAGNWDOTFile