



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH0632412

ODOT REST AREA 7-26

6/22/2011



Re: Auglaize County
ODOT Rest Area 7-26 PWS
NTNC Public Water System
PWS ID# 0632412

June 22, 2011

Mr. Lonnie Falknor
1001 St. Marys Avenue
P. O. Box 969
Sidney, Ohio 45365

**Notice of Violation – Monthly Report – Chlorine Residual Distribution
Notice of Deficiency – Monthly Report – Chlorine Residuals – Plant Tap**

Dear Mr. Falknor:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system May 3, 13, 19, 20, 24, and 31

OAC Rule 3745-83-01 (C) (1) requires all noncommunity public water systems serving at least 1,000 people to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.


Notice of Deficiency

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l on May 6, 13, and 20, at the plant tap. Investigate the cause of this deficiency and take measures to correct it.

Mr. Lonnie Falknor
June 22, 2011
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,



Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/lr

pc: Auglaize County Health Department
DDAGW-NWDO-File