



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Auglaize County
ODOT Rest Area 7-26 PWS
TNC Public Water System
PWS ID# OH0632412

March 18, 2011

OH0632412

ODOT REST AREA 7-26

3/18/2011

Mr. Lonnie Falknor
1001 St. Marys Avenue
P. O. Box 969
Sidney, Ohio 45365



**Notice of Violation – Monthly Report – Chlorine Residual Distribution
Notice of Deficiency – Monthly Report – Chlorine Residuals – Plant Tap**

Dear Mr. Falknor:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system February 8, 19, 22, 24, and 25.

OAC Rule 3745-83-01(C)(1) requires all noncommunity public water systems serving at least 1,000 people to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

Notice of Deficiency

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l on February 7, 8, 19, 20, 24, and 28 at the plant tap. Investigate the cause of this deficiency and take measures to correct it.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to chris.riddle@epa.state.oh.us.

Sincerely,

Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/cs

pc: Auglaize County Health Department
~~NWDG~~ = DDAGW:File

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov