



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

RE: Auglaize County
ODOT Rest Area 7-26 PWS
TNC Public Water System
PWS ID# OH0632412

November 18, 2010

OH0632412

ODOT REST AREA 7-26

11/18/2010

Mr. Lonnie Falknor, Administrative Contact
1001 St Marys Ave
PO Box 969
Sidney, OH 45365-0969



Notice of Violation – Monthly Report

Dear Mr. Falknor:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) for the October, 2010 reporting period, reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system on October 1, 2, 11, 15, 16, 17, 18, 23, 24, 25, and 28, 2010.

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

On October 20 and 26, chlorine residual (free) of 2.2 mg/l were reported indicating the upper detection limit of the test kit was reached. In the future, if the display reports an over range (flashing 2.2 in display); follow instructions supplied by the manufacturer of the test kit to analyze a second sample using either a higher range of detection or by dilution of the sample so as to determine and report the concentration present in the sample.

On October 11, chlorine residual (free) within the distribution system was not reported. OAC Rule 3745-83-01 (G)(1) requires free chlorine to be monitored daily from a representative point in the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3042 or via e-mail to Larry.Moritz@epa.state.oh.us.

Sincerely,

Larry W. Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters
/lb

cc: Ann Scott, Operator
Auglaize County Health Department

~~INWDO-DDAGW~~