



Environmental Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Auglaize County  
ODOT Rest Area 7-34 WB PWS  
NTNC Public Water System  
PWS ID# OH 0634112  
STU ID# 652943


July 15, 2011

OH0634112

ODOT REST AREA 7-34 WB

7/15/2011

Mr. Lonnie Falknor  
1001 St. Marys Avenue  
P. O. Box 969  
Sidney, Ohio 45365



**Failure to report chlorine residual free or combined daily in the distribution system**

Dear Mr. Falknor:

Notice of Violation

In violation of OAC 3745-83-01 (F)(2), the public water system failed to report free or combined chlorine residual daily in the distribution system. There were three (3) days during the month of June in which the analysis was not performed.

OAC Rule 3745-83-01 (C) (1) requires all noncommunity public water systems serving at least 1,000 people to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to [Chris.Riddle@epa.state.oh.us](mailto:Chris.Riddle@epa.state.oh.us).

Sincerely,

Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/llr

pc: Auglaize County Health Department

DDAGW-NWDO File