



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Auglaize County
ODOT Rest Area 7-33 EB PWS
NTNC Public Water System
PWS ID# OH 0634012
STU ID# 652942

May 24, 2011

OH0634012

ODOT REST AREA 7-33 EB

5/24/2011

Mr. Lonnie Falknor
1001 St. Marys Avenue
P. O. Box 969
Sidney, Ohio 45365



Failure to report chlorine residual (free/combined) daily at the (plant tap/distribution system); 3 days or more - NOV OAC 3745-83-01 (F)(2)

Dear Mr. Falknor:

In violation of OAC 3745-83-01 (F)(2), the public water system failed to report free or combined chlorine residual daily in the distribution system. There were three (3) days during the month in which the analysis was not performed.

OAC Rule 3745-83-01 (C) (1) requires all noncommunity public water systems serving at least 1,000 people to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,

Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/l/r

pc: Auglaize County Health Department
DDAGW-NWDO File

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov