




State of Ohio Environmental Protection Agency

Northwest District OH1733712 ST PAUL LUTHERAN CH - SULPHUR SPRING 22 04/23/10

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 F
www.epa.ohio.gov



NOTICE OF VIOLATION – ACTION REQUIRED

RE: Crawford County
St. Paul Lutheran Church - Sulphur Spring
Non-Community, Transient
PWS ID: OH1733712

April 23, 2010

Mr. Marvin Kocher
St. Paul Lutheran Church - Sulphur Spring
4707 Ridgeton-Annapolis Road
P.O. Box 157
Sulphur Springs, Ohio 44881-0157

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During Second Quarter of 2010 (Monthly)**

St. Paul Lutheran Church - Sulphur Spring is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
04-14-10	None Given	Positive	Negative	--	1028	838
04-22-10	Kitchen Sink	Positive	Negative	--	1119	838
04-22-10	Men's Restroom	Positive	Negative	--	1120	838
04-22-10	Utility Sink	Positive	Negative	--	1121	838
04-22-10	Women's Restroom	Positive	Negative	--	1122	838

ACTION REQUIRED:

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;



Mr. Marvin Kocher
April 23, 2010
Page Two

- Mail or other direct delivery to each customer;
- Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

3. Complete the enclosed verification form within 10 days of issuing the Public Notice and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.

4. Monitor with at least five (5) routine samples in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to monitor with five (5) routine samples during May 2010.

If you have any questions, contact this office at 419-373-3007.

Sincerely,



Robert A. Plotts
Division of Drinking and Ground Waters

/lb

Enclosures: Tier 2 Public Notification (2)
Public Notice Instructions and Verification Form

pc: Crawford County Health Department
Information Management Section, DDAGW, CO

~~DDAGW-NWDO (w/enclosures)~~

DRINKING WATER NOTICE

Tests show coliform bacteria in St. Paul Lutheran Church - Sulphur Spring water

We routinely monitor for the presence of drinking water contaminants. We took five (5) samples for coliform bacteria during April 2010. All of those samples showed the presence of coliform bacteria. No more than one (1) sample may show the presence of coliform bacteria during a month.

What should I do?

- *You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.*
- *Total coliform bacteria are generally not harmful themselves. Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution system.*
- *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. Fecal coliform or E. coli, which are bacteria of greater concern, were not detected in the water.*

What is being done?

We are still detecting coliform bacteria. We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact _____ at _____
name of contact phone number
or at _____
mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID# OH1733712

Date Distributed:

PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR NON-COMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS

The owner or operator of a non-community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p>Use one or more of the following methods to reach all persons served by the public water system:</p> <p>1. Public notice issued by posting in conspicuous locations throughout the distribution system (required to remain posted for as long as the violation exists, but in no case less than 7 days)</p> <p>2. Public notice issued by mail or other direct delivery to each customer and service connection (where known).</p>	<p>Describe actual methods used to notify public of the violation:</p> <p>1A. Dates of posting _____</p> <p>1B. Locations of posting _____ _____</p> <p>2. Date of mailing/delivery _____</p>
<p>Schools and Day-Care Facilities must notify parents or guardians of children being served by methods besides posting, such as a newsletter, e-mail notice, or direct mailing</p>	<p>A. Method(s) _____ _____</p> <p>B. Date(s) _____</p>
<p>If the above methods do not reach all persons served, also use any other method reasonably calculated to reach other persons served by the system (e.g. publication in a local newspaper or newsletter, use of e-mail to notify employees or students, or delivery of multiple copies to central locations).</p>	<p>A. Method(s) _____ _____</p> <p>B. Date(s) _____</p>

Complete the enclosed verification form and mail it to Ohio EPA – NWDO. INCLUDE A COPY OF THE PUBLIC NOTICE.

Signature of Responsible Person Date

Printed Name and Title of Responsible Person

St. Paul Lutheran Church - Sulphur Spring
OH1733712
Crawford County
Second Quarter of 2010
Total Coliform Monthly MCL (Vio. Type 22)

<p>For Ohio EPA use only: Date PN received: _____ PN acceptable: _____ PN not acceptable: _____</p>
--