




Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH1736912

SUNSET SPRINGS CAMPGROUND-N WELL

7/21/2011



Re: Crawford County
Sunset Springs Campground - N Well
Transient Non-Community
Public Water System
PWS ID# OH1736912
STU ID# 1753703

July 21, 2011

Ms. Judy Holzmilller
WBSA, Inc. DBA Sunset Springs Campground
3933 Hensing Road
P. O. Box 444
Oceola, Ohio 44860-0444

Dear Ms. Holzmilller:

On July 11, 2011, Ryan Sendelbach of the Crawford County Health Department provided Ohio EPA with photographs and a description of an extension of waterlines from your public water system to a previously unserved area of your campground facility.

Ohio Administrative Code (OAC) Rule 3745-91-01(C)(1) includes the installation of new waterlines in the definition of a "substantial change" to a public water system. OAC Rule 3745-91-02(A) strictly prohibits making a substantial change to a public water system until plans for the proposed change have been approved by the director of Ohio EPA.

No plans have been submitted, reviewed, or approved for this waterline extension.


WBSA, Inc. is in violation of OAC Rule 3745-91-02(A) for failing to receive approval for a substantial change to a public water system prior to executing the change.

To correct this violation, submit detailed plans and specifications for the waterline extension to Ohio EPA for review. Enclosed for your convenience is a blank Water Supply Data Sheet, which must be completed and submitted with the plans submittal. If you have any questions concerning preparation of plans or the plan review process, please contact Ralph Baker, Engineer, at 419-373-3048.

Ms. Judy Holzmilller
July 21, 2011
Page 2

If you have any other questions concerning you water system, please contact me at
419-373-3102.

Sincerely,



Kimberly K. Burnham, R.S.
Division of Drinking and Ground Waters

//lr

pc: Crawford County Health Department
DDAGW, NWDO File

ec: Paul Brock, PE, DDAGW, NWDO
Ralph Baker, DDAGW, NWDO