



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Re: Defiance County
Hickory Hills Golf Club
TNC Water System
PWS ID # OH2032012

December 10, 2009

OH2032012

HICKORY HILLS GOLF CLUB

12/10/2009

Mr. Darren Brown
Hickory Hills Golf Club
01544 State Route 18
Hicksville, Ohio 43526



Dear Mr. Brown:

This letter will confirm removal of the water use advisory required in our letter dated December 8, 2009. This is based on one set of four total coliform negative (safe) samples collected December 3, 2009 and received by our office December 8, 2009.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by December 24, 2009.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of December 2009.

Yours truly,

Robert A. Plotts
Division of Drinking and Ground Waters

/lb

pc: Defiance County Health Department
Data Management Section, DDAGW, CO, Attn: Toni Buchanan

DDAGW, NWDO

