



Environmental Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Defiance County  
Transient NC PWS  
St. Isidore Catholic Parish  
PWS ID# OH 2032412  
STU ID# 2053855

August 18, 2011

OH2032412

ST ISIDORE CATHOLIC PARISH

8/18/2011

Mr. Robert Kill  
05480 Moser Road  
Defiance, Ohio 43512



Dear Father Kill:

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

This letter is notification that the St. Isidore Catholic Parish has not complied with requirements issued during this Agency's last survey performed on June 24, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code. **The PWS was notified in correspondence dated July 7, 2011, to respond in writing no later than 30 days, with time frames for:**

- 1.) OAC Rule 3745-9-05 (O) states, "Well casing height above finished grade shall be at least twelve inches..." In addition, OAC Rule 3745-9-05 (O)(2) states, "The finished grade shall be sloped for surface water runoff away from the well."

The finished grade must be sloped away from each well in accordance with OAC Rule 3745-9-05 (O)(2) and the height of each well casing must be at least twelve inches above finished grade. Contact a well driller to install an extension on the well casing to achieve the required height.

- 2.) Public notice for a coliform sampling violation in January 2010 has not been posted. Copies of the notice have been provided. Post the required notice and complete and return the verification form.

**The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.**

Mr. Robert Kill  
August 18, 2011  
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, contact me at 419-373-3101.

Sincerely,



Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/llr

pc: Defiance County Health Department  
Dave Bornino, DDAGW, Operations CO - with enclosures  
~~DDAGW--NWDO File with enclosures~~