



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Defiance County
St. Isidore Catholic Parish
TNC Water System
PWS ID # OH2032412

March 10, 2010

OH2032412

ST ISIDORE CATHOLIC PARISH

3/10/2010

Father Robert Kill
St. Isidore Catholic Parish
05480 Moser Road
Defiance, Ohio 43512



Dear Father Kill:

This letter will confirm removal of the water use advisory required in our letter dated February 2, 2010. This is based on one set of total coliform negative (safe) samples collected March 3, 2010.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by March 19, 2010.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It was the responsibility of the water system to have collected five routine samples during the month of February 2010.

Yours truly,

Robert A. Plotts
Division of Drinking and Ground Waters

/llr

pc: Defiance County Health Department
Data Management Section, DDAGW, CO, Attn: Toni Buchanan
DDAGW, NWDO File