



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Fulton County
White City Restaurant
TNC Water System
PWS ID # OH2631212


April 4, 2008

OH2631212

WHITE CITY RESTAURANT

4/4/2008

White City Restaurant
10938 U.S 20
Lyons, Ohio 43533



This letter will confirm removal of the water use advisory required in our letter dated March 27, 2008. This is based on one set of four total coliform negative (safe) samples collected April 1, 2008.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by April 18, 2008.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five routine samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five routine samples during the month of April 2008.

Yours truly,

Robert A. Plotts
Division of Drinking and Ground Waters

/csl

pc: Fulton County Health Department
Data Management Section, DDAGW, CO, Attn: Toni Buchanan
DDAGW, NWDO