



Northwe



TELE: (419) 3

* 0 H 2 6 3 1 2 1 2 8 5 2 9 8 0 7 *

347 North Dunbridge Road
Bowling Green, OH 43402-9398

Re: Fulton County
White City Restaurant
TNC Water System
PWS ID# OH2631212

October 19, 2007

Mr. Jad Sweidan
White City Restaurant
10938 U.S. Route 20
Lyons, Ohio 43533

Dear Mr. Sweidan:

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

- Monitoring Period:** September 2007
- Required Coliform Sampling:** Five samples in the month after a coliform-positive
- Sample Results Submitted:** Four samples on September 10, 2007

Actions required as a result of the above violation:	
Step 1	<p>Within 30 days issue public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> 1. continuous posting, mail, or other direct delivery; and 2. if necessary, the system must also use any other method reasonably calculated to reach all persons.
Step 2	<p>Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.</p>

If you have any questions, please contact me at (419) 373-3007.

Sincerely,

Robert A. Plotts
Division of Drinking and Ground Waters

/cs/
Enclosures
pc: Toni Buchanan, DDAGW, CO
Fulton County Health Department
DDAGW, NWDO File