




Northwe:



347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 35  
ww

Re: Fulton County  
White City Restaurant  
TNon-Community Water System  
PWS ID # OH2631212

September 18, 2007

Mr. Jad Sweidan  
White City Restaurant  
10938 U.S. Route 20  
Lyons, Ohio 43533

Dear Mr. Sweidan:

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Your public water system incurred a **monthly** violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in August 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.

Sample Date	Sample Tap	Total Coliform	Fecal Coliform	<i>E. coli</i>	Sample Number	Lab Cert. Number
08-28-07	3 Compartment Sink	Positive	Negative	--	35947	877
09-10-07	3 Compartment Sink	Positive	Negative	--	231881	877
09-10-07	3 Compartment Sink	Positive	Negative	--	231882	877

Actions required as a result of the above violation	
Step 1	<b>Within 30 days</b> issue the enclosed public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:  Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.).
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing <b>Step 1</b> above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in October 2007. You also need to take one (1) more sample in September 2007.

Mr. Jad Sweidan  
September 18, 2007  
Page Two

If you have any questions, please contact me at (419) 373-3007.

Sincerely,

Robert A. Plotts  
Division of Drinking and Ground Waters

JKS/lb

Enclosures

pc: Toni Buchanan, DDAGW, CO  
Fulton County Health Department  
DDAGW-NWDO File

5842 7990 1000 054E 9002

<b>U.S. Postal Service™</b>	
<b>CERTIFIED MAIL™ RECEIPT</b>	
<i>(Domestic Mail Only; No Insurance Coverage Provided)</i>	
For delivery information visit our website at <a href="http://www.usps.com">www.usps.com</a> ®	
<b>OFFICIAL USE</b>	
Postage	\$ 41
Certified Fee	2.65
Return Receipt Fee (Endorsement Required)	2.15
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$ 521

Postmark Here: **OHIO EPA SEP 13 2007**

Sent To	Mr. Jad Sweidan
Street, Apt. No., or PO Box No.	White City Restaurant 10138 US Route 20
City, State, ZIP+4	Scio OH 43533

PS Form 3800, August 2006 See Reverse for Instructions