



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Hancock County
Jenera Community Building
TNC Water System
PWS ID # OH3235212

August 11, 2011

OH3235212

JENERA COMMUNITY BUILDING

8/11/2011

Mr. Don Klinger
Jenera Community Building
103 South Main Street
P. O. Box 57
Jenera, Ohio 45841



Dear Mr. Klinger:

This letter will confirm removal of the water use advisory required in our letter dated July 29, 2011. This is based on one set of four total coliform negative (safe) samples collected August 1, 2011.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by August 25, 2011.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of August 2011.

Yours truly,

Jill A. Schiefer
Division of Drinking and Ground Waters

/llr

pc: Hancock County Health Department
IMS, DDAGW, CO, Attn: Toni Buchanan
~~DDAGW, NWDO~~