



347 North Dunbridge Road  
Bowling Green, OH 43402-9398

Northwe:

TELE: (419) 352

www.



**NOTICE OF VIOLATION – ACTION REQUIRED**

September 29, 2009

RE: Hancock County  
Jenera Community Building  
Non-Community, Transient  
PWS ID: OH3235212

Mr. Don Klinger  
Jenera Community Building  
103 South Main Street  
P.O. Box 57  
Jenera, Ohio 45841

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During September 2009 (Monthly)**

Jenera Community Building is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
09-23-09	Outside Spigot	Positive	Negative	--	16546	833
09-23-09	Women's RR Sink	Positive	Negative	--	16542	833

**ACTION REQUIRED:**

- Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.




Mr. Don Klinger  
September 29, 2009  
Page 2

- Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
- Mail or other direct delivery to each customer;
- Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to monitor with five (5) routine samples during October 2009. You are also required to monitor with one (1) additional routine sample during September 2009.

If you have any questions, contact this office at 419-373-3089.

Sincerely,



Jill A. Schiefer  
Division of Drinking and Ground Waters

/csf

Enclosures: Tier 2 Public Notification (2)  
Public Notice Instructions and Verification Form

pc: Hancock County Health Department  
Information Management Section, DDAGW, CO  
District File Copy (w/enclosures)