



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH3244012

ODOT REST AREA 1-26 SB

5/17/2011



Re: Hancock County
ODOT Rest Area 1-26 SB
TNC Water System
PWS ID# 3244012
STU ID# 3254856

May 17, 2011

Mr. Kirk Slusher, District Deputy Director
ODOT- District 1
1885 North McCullough Street
Lima, Ohio 45802

RE: Notice of Violation – Monthly Report

Dear Mr. Slusher:

The April 2011, Plant – Distribution Monthly Operation Report (EPA Form 5002) was received by the Ohio EPA-Northwest District Office on May 9, 2011.

OAC Rule 3745-83-01(C)(1) requires a system which adds chlorine to maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system. A review of March 2011 report shows 4 days during the month a chlorine residual was not being maintained in the distribution system. Take steps to immediately correct this problem.

ODOT Rest Area 1-26 SB no longer needs to monitor for pH, Stability, Iron and Manganese.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Hancock County Health Department
~~NWDO~~ DDAGW:File
ec: Ann Scott, IFM
Tony Lotz, Facilities Manager