



**Environmental Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

OH3246512 FINDLAY/VAN BUREN KOA KAMPGROUND- W 22 07/29/10



**NOTICE OF VIOLATION – ACTION REQUIRED**

August 2, 2010

Re: Hancock County  
Pleasant View RV Resort - West  
Non-Community, Transient  
PWS ID: OH3246512

Mr. Randal N. Perry  
Pleasant View RV Resort  
12611 Township Road 218  
P. O. Box 255  
Van Buren, Ohio 45889

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL) During Third Quarter of 2010 (Monthly)**

Pleasant View RV Resort - West is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
07-20-10	None Given	Positive	Negative	--	495	245
07-27-10	None Given	Positive	Negative	--	519	245
07-27-10	None Given	Positive	Negative	--	520	245

**ACTION REQUIRED:**


- Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Mail or other direct delivery to each customer;
  - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

Mr. Randal N. Perry  
August 2, 2010  
Page Two

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to monitor with five (5) routine samples during August 2010.

If you have any questions, contact this office at 419-373-3089.

Sincerely,



Jill A. Schiefer  
Division of Drinking and Ground Waters

JKS/cs

Enclosures: Tier 2 Public Notification (2)  
Public Notice Instructions and Verification Form  
Level 1 Assessment

pc: Hancock County Health Department  
Information Management Section, DDAGW, CO  
~~DDAGW~~ = NWDO (w/enclosures)