



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Hancock County
Pleasant View Resort - West
TNC Public Water System
PWS ID# OH3246512
STU ID# 3254879


June 3, 2010

Mr. Randy Perry, Owner
Pleasant View Resort
12611 Township Road 218
P. O. Box 255
Van Buren, Ohio 45890

OH3246512

PLEASANT VIEW RESORT- WEST

6/3/2010



Dear Mr. Perry:

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that the Pleasant View Resort – West has not complied with requirements issued during this Agency’s last survey performed on March 10, 2010, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in correspondence dated March 30, 2010, to respond in writing no later than 45 days, with time frames for:

- OAC Rule 3745-9-04 (A)(6) states, "Potential sources of contamination shall not be constructed or placed within the sanitary isolation radius of a public water system well."

The required isolation radius for the well is 90 feet. However, sewer lines (potential sources of contamination) are located within the isolation radius. To document the well has the appropriate isolation, provide a map of the property showing the well, the isolation radius and everything within the isolation radius. If the well does not have the isolation required, all sources of contamination must be removed from within the required isolation distance of the well. Alternatively, submit a contingency plan for providing water in the event that the well fails. The plan should include a map of the property showing the location of a new well(s) with the required isolation distance clearly marked of this is one of your options.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions regarding this letter, or any other matter involving your water system, contact me at 419-373-3089 or via email at jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Environmental Specialist
Division of Drinking and Ground Waters

/cs
pc: Hancock County Health Department
Dave Bornino, DDAGW, Operations CO
DDAGW=NWBO File

