



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Hancock County  
Shadylake Campground  
TNC Water System  
PWS ID# OH3240112  
STU ID# 3254838

August 24, 2009

Mr. Terry Rowland, Owner  
Shadylake Campground  
11506 Township Road 101  
Findlay, Ohio 45840

OH3240112

SHADYLAKE CAMPGROUND

8/24/2009



Dear Mr. Rowland:

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

This letter is notification that the Shadylake Campground has not complied with requirements issued during this Agency's last survey performed on May 5, 2009, in violation of Rule 3745-81-60 of the Ohio Administrative Code (OAC). The campground was notified in correspondence dated May 19, 2009, by Larry Moritz of this office, to respond in writing no later than 45 days after the date of the letter, with time frames for:

1. Install a vented well cap on well #1 constructed in conformance with "Water System Council Pitless Adapter Standard PAS-97, Performance Standards for Sanitary Well Pitless Adapters, Pitless Units, and Watertight Well Caps". (OAC Rule 3745-9-05(P))
2. Install a vent on well #2 that is self-draining, screened with a non-corroding mesh screen of fifteen- to thirty-mesh, pointed downward. The vent is to terminate no less than twelve (12) inches above the well house floor. (OAC Rule 3745-9-05(T)).
3. Install a new sanitary seal on Well #2 and maintain the seal such that overhead debris may not be introduced into the well.
4. Prepare and retain a copy of the Total Coliform Sample Siting plan for each area of the campground water systems. (OAC Rule 3745-81-21)
5. Have the backflow device located at the dump station inspected by a certified plumber to verify it meets the appropriate plumbing code. At the time of the inspection, it appeared to be inadequate and not in conformance with OAC 3745-95-06.


The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.



Mr. Terry Rowland  
August 25, 2009  
Page Two

If you have any questions, please contact me at (419) 373-3089 or via email at [jill.schiefer@epa.state.oh.us](mailto:jill.schiefer@epa.state.oh.us).

Sincerely,



Jill A. Schiefer  
Environmental Specialist  
Division of Drinking and Ground Waters

/cs

pc: Hancock County Health Department  
DDAGW-CO  
DDAGW-NWDO File  
NWDO Follow-up File