



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

Re: Hardin County  
Hi-Road Drive-In Theatre  
TNC Public Water System  
PWS ID#OH3331312  
STU ID#3354904


September 15, 2010

OH3331312

AVALON ENTERTAINMENT

9/15/2010

Mr. Rodney Miller  
106 West Pike Street  
P. O. Box 477  
Jackson Center, Ohio 45334



Dear Mr. Miller:

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

This letter is notification that the Hi-Road Drive-In Theatre Public Water System has not complied with requirements issued during this Agency's last survey performed on July 12, 2010, in violation of Ohio Administrative Code (OAC) rule 3745-81-60. Correspondence dated July 22, 2010, required a written response within 45 days, with a time frame for resolving the following issues:

1. OAC Rule 3745-9-05 (P) states, "A well cap for a public water system well shall conform with "Water System Council Pitless Adapter Standard PAS-97, Performance Standards for Sanitary Water Well Pitless Adapters, Pitless Units, and Watertight Well Caps (1997)". OAC Rule 3745-9-05 (T) states: "A vent shall be provided on all well caps ... A well vent shall be self-draining, screened with a noncorroding mesh screen of fifteen to thirty mesh, pointed downward at or above the top of the casing or pitless unit. A vent shall terminate not less than twelve inches above ground surface, and at least twelve inches above the well house floor or concrete apron surface.

The well cap lacked an integrated screened vent. The well cap shall be replaced with one that conforms with "Water System Council Pitless Adapter Standard PAS-97, Performance Standards for Sanitary Water Well Pitless Adapters, Pitless Units, and Watertight Well Caps" (1997) (OAC rule 3745-9-05 (P)) .

2. OAC Rule 3745-9-04 (A)(6) states, "Potential sources of contamination shall not be constructed or placed within the sanitary isolation radius of a public water system well." The required isolation radius for the well is 55 feet. To document the well has the appropriate isolation, provide a map of the property showing the well, the isolation radius and everything within the isolation radius.

Mr. Rodney Miller  
September 15, 2010  
Page 2

If the well does not have the isolation required, all sources of contamination must be removed from within the required isolation distance of the well. Alternatively, submit a contingency plan for providing water in the event the well fails. The plan should include a map of the property showing the location of a new well(s) with the required isolation distance clearly marked.

3. OAC Rule 3745-81-21 (A) requires a public water system to collect total coliform samples at sites which are representative of water throughout the distribution system according to a written sample siting plan. Complete and maintain a written sample siting plan for total coliform monitoring in accordance with the enclosed guidance document.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419.373.3042 or [Larry.Moritz@epa.state.oh.us](mailto:Larry.Moritz@epa.state.oh.us)

Sincerely,



Larry W. Moritz  
Division of Drinking and Ground Waters

/llr

pc: Hardin County Health Department  
DDAGW-CO/OFAS  
{DDAGW-NWDO-File.....}

ec: JoAnn Sabo, DOCC, DDAGW-NWDO