



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Hardin County
Sugar Grove United Methodist Church
T Non-Community Water System
PWS ID # OH3333512

December 31, 2007

Mr. Bradley Hays
Sugar Grove United Methodist Church
4945 State Route 81
Ada, Ohio 45810

OH3333512 SUGAR GROVE UNITED METHODIST CHURCH 23 10/30/07



Dear Mr. Hays:

Subject: Additional Total Coliform Samples Required

The result of a recent sample submitted for bacteriological analysis is as follows:

Sample Date	Sample Tap Location	Result			Sample/Lab Number
		Total Coliform	Fecal Coliform	E. Coli	
12-26-07	Tap after Softener	Positive	-	Negative	13019 / 833

When a bacteriological sample is total coliform positive (unsafe), four repeat samples must be collected. Do not disinfect the well before collecting repeat samples from the following location:

- a. The same sample tap as the total coliform positive (unsafe) sample.
- b. A sample tap within five service connections upstream (before) from the positive (unsafe) tap.
- c. A sample tap within five service connections downstream (after) from the positive (unsafe) tap.
- d. Another sample tap within five service connections upstream or downstream (between b. and c.) from the positive (unsafe) tap.

NOTE: If only one sample tap is available, four repeat samples should be collected from that tap at least five (5) minutes apart with the water continuously running OR take the samples at 30-minute intervals.

IMPORTANT INFORMATION

- * Collect all four (4) repeat samples on the same day.
- * **Collect the four repeat samples immediately. If we do not receive the results by January 9, 2008, your water system will be placed on a water use advisory.**
- * Identify the exact sample tap on each Sample Submission Report.
- * Mark the Sample Class "REPEAT SAMPLE".
- * Record Sample #13019 on the line after Repeat for Sample #.

Mr. Bradley Hayes
December 31, 2007
Page 2

If any of the repeat samples are total coliform positive (unsafe), collect additional sets of four repeat samples until a complete set of four samples is total coliform negative (safe) or until the Maximum Contaminant Level is exceeded.

Monitor with at least five (5) routine samples in the next month following any total coliform positive result. Collect at least five (5) routine samples during the month of January, 2008.

If you have any questions, please contact me at (419) 373-3042.

Sincerely,



Larry Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters

JW/lir

pc: Hardin County Health Department (faxed)
DDAGW, NWDO