



State of Ohio Environmental Protection Agency

North OH3335212 VETERANS MEMORIAL PARK

22 06/28/10

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (



* 0 H 3 3 3 5 2 1 2 8 5 4 7 0 0 9 *

remor
remor
irector

Re: Hardin County
Veterans Memorial Park
Non-Community, Transient
PWS ID: OH3335212

June 29, 2010

NOTICE OF VIOLATION – ACTION REQUIRED

Ms. Cindy Beverly
Veterans Memorial Park
One Courthouse Square
Suite 210
Kenton, Ohio 43326

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During Second Quarter of 2010 (Monthly)**

Veterans Memorial Park is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
06-14-10	Kitchen Sink	Positive	Negative	--	104391	877
06-21-10	Proshop Kitchen Tap Sink	Positive	Negative	--	277244	877
06-21-10	Proshop Bar Sink	Positive	Negative	--	277245	877
06-21-10	Men's Restroom Sink	Positive	Negative	--	260405	877

ACTION REQUIRED:

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;



Ms. Cindy Beverly
June 29, 2010
Page 2

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to monitor with five (5) routine samples during July 2010.

If you have any questions, contact this office at 419-373-3042.

Sincerely,



Larry W. Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters

//lr

Enclosures: Tier 2 Public Notification (2)
Public Notice Instructions and Verification Form

pc: Hardin County Health Department
Information Management Section, DDAGW, CO
(DDAGW-NWDO-(w/enclosures)→