



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Hardin County
Walnut Grove UM Church
TNC Public Water System
PWS ID# OH3334212
STU ID# 3354925

September 18, 2009

CERTIFIED MAIL

OH3334212

WALNUT GROVE UNITED METHODIST
CHURCH

9/18/2009

Mr. Chris Rodabaugh
Administrative Board Chairman
Walnut Grove United Methodist Church
1361 Township Road 125
Dunkirk, Ohio 45836



Dear Mr. Rodabaugh:

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that the Walnut Grove United Methodist Church Public Water System has not complied with requirements issued during this Agency's last survey performed on July 7, 2009, in violation of Ohio Administrative Code (OAC) rule 3745-81-60. Correspondence dated July 17, 2009, required a written response within 45 days, with a time frame for resolving the following issues:

1. Routine coliform bacteria samples must be collected from the distribution system, after all treatment, according to your sample siting plan. A Sample Siting Plan for Total Coliform Monitoring shall be created in accordance with OAC rule 3745-81-21.
2. If the iron (filter) is not to be maintained, the equipment shall be physically removed from the distribution system. OAC Chapter 3745-91 requires the approval of plans prior to making a substantial change to the public water system. Questions related to preparation of a plan submittal package can be directed to Ralph Baker at 419-373-3048.
3. The well has not been demonstrated to be sited in conformance with OAC Rule 3745-9-04 which establishes, based upon the estimated average daily water demand, a sanitary isolation radius from potential sources of contamination. The required isolation radius has been established as 50 feet based upon an average daily water demand of 1,620 gallons per day. Submit a plan for establishing an alternate well site or source of water in the event the existing source should fail.
4. The well cap lacks an integrated screened vent as required by OAC rule 3745-9-05 P. Replace the well cap.
5. OAC Rule 3745-83-01 (D) states that, "All chemicals, substances and materials added to or brought in contact with water in or intended to be used in a public water system... shall be shown by either the manufacturer, distributor, or purveyor to be non-toxic and harmless to humans when used in accordance with the formulation and concentration as specified by the manufacturer, and shall conform with the "American National Standards



Mr. Chris Rodabaugh
September 18, 2009
Page Two

Institute/National Sanitation Foundation" (ANSI/NSF) standard 60 Drinking Water Treatment Chemicals - Health Effects (2005 and previous), or standard 61 Drinking Water System Components - Health Effects (2005 and previous). The salt used in the production of brine for the system is not labeled as an NSF approved product. Submit documentation to Ohio EPA, NWDO that the salt conforms with ANSI/NSF standard 60.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419.373.3042 or Larry.Moritz@epa.state.oh.us.

Sincerely,



Larry W. Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters

/lb

cc: Jeff Waite, Pastor
Jerry Jollif, Trustee
Hardin County Health Dept.
Dave Bornino, C.O. - DDAGW / OFAS
~~DDAGW/NWDO~~
7007 2560 0000 4479 2438

ec: JoAnn Sabo, District Office Compliance Coordinator
Larry Gamble, Engineering Supervisor, NWDO, DDAGW

DDAGW-LM-LB

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY
<ul style="list-style-type: none"> ■ Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. ■ Print your name and address on the reverse so that we can return the card to you. ■ Attach this card to the back of the mailpiece, or on the front if space permits. 	<p>A. Signature <input checked="" type="checkbox"/> Agent <input checked="" type="checkbox"/> Addressee</p> <p>B. Received by (Printed Name) C. Date of Delivery Chris Rodabaugh 9-22-09</p> <p>D. Is delivery address different from item 1? <input type="checkbox"/> Yes If YES, enter delivery address below: <input checked="" type="checkbox"/> No</p>
<p>1. Article Addressed to:</p> <p style="font-family: cursive;">Mr Chris Rodabaugh Adm Board Chairman Walnut Grove UMC Church 1361 Township Rd 125 Dunkirk Oh 45836</p>	<p>3. Service Type</p> <p><input type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.</p> <p>4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes</p>
<p>2. Article Number (Transfer from service label)</p>	<p>7007 2560 0000 4479 2438</p>
PS Form 3811, February 2004 Domestic Return Receipt 102595-02-M-1540	

DDAGW-LM-LB

U.S. Postal Service™		CERTIFIED MAIL™ RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)		
For delivery information visit our website at www.usps.com		
OFFICIAL USE		
	Postage	\$.44
	Certified Fee	2.80
	Return Receipt Fee (Endorsement Required)	2.30
	Restricted Delivery Fee (Endorsement Required)	
	Total Postage & Fees	\$5.54
<div style="border: 1px solid red; border-radius: 50%; padding: 10px; display: inline-block;"> OHIO EPA SEP 21 11 BOWLING GREEN OH 43302 </div>		
Sent To Street, Apt. No., or PO Box No. City, State, ZIP+4		
Mr Chris Rodabaugh Walnut Grove UMC Church 1361 Township Rd 125 Dunkirk Oh 45836		
PS Form 3800, August 2006		See Reverse for Instructions

7007 2560 0000 4479 2438