



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

OH3533412 LIBERTY CHAPEL U M CHURCH

25 09/10/09

Re: Henry County
Liberty Chapel U M Church
Non-Community, Transient
PWS ID: OH3533412



September 11, 2009

Mr. Jeremy Carico
Liberty Chapel U M Church
110 East Street
P.O. Box 92
Liberty Center, Ohio 43532

NOTICE OF VIOLATION – ACTION REQUIRED

Subject: Failure to Conduct Required Repeat Total Coliform Monitoring

Liberty Chapel U M Church is in violation of monitoring requirements for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-21 for August 2009.

Ohio EPA records indicate that a total coliform-positive sample was collected from this water system on 8/25/2009 and the required repeat samples were not collected. To ensure the safety of drinking water provided by your system monitoring with all of the required repeat samples is essential.

IMMEDIATE ACTION REQUIRED:

- 1. Consult with Ohio EPA within 24 hours** regarding public notice requirements. If you have not already received direction regarding this violation, contact the NWDO at 419-373-3144 .
- 2. Issue the enclosed public notice within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served.
 - Hand delivery to persons served by the water system;
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Send to parents or guardians of children at schools or day care facilities;
 - Another delivery method approved in writing by the director;



Mr. Jeremy Carico
September 11, 2009
Page 2

- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven (7) days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

NOTE: Issuance of a Public Notice must be repeated every 30 days for as long as the violation exists, unless directed otherwise by the District Office. A verification form and a copy of the public notice, stating the corrective measures completed to date, must be submitted to the Ohio EPA.

3. **Complete the enclosed verification form, within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.
4. **Collect a set of four (4) repeat samples, until one set is total coliform-negative to discontinue the Water Use Advisory.** Notify the people served by the water system when the water use advisory is discontinued.
5. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to monitor with five (5) routine samples during September 2009.

If repeat samples were collected, submit them as soon as possible.

If you have any questions, contact this office at 419-373-3007.

Sincerely,



Robert A. Plotts
Division of Drinking and Ground Waters

/l/r

Enclosures: Tier 1 Public Notification (2)
Public Notice Instructions and Verification Form

pc: Henry County Health Department
Information Management Section, DDAGW, CO
DDAGW = NWDO (w/enclosures)