



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

OH3533412 LIBERTY CHAPEL U M CHURCH

22 08/18/09



Re: Henry County  
Liberty Chapel U M Church  
Non-Community, Transient  
PWS ID: OH3533412

August 19, 2009

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. Max Fetterman  
206 Briarcliff Drive  
Liberty Center, Ohio 43532

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During August 2009 (Monthly)**

Liberty Chapel U M Church is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
08-02-09	Coffee Bar	Positive	Negative	--	9237	470
08-10-09	Upper Men's RR	Positive	Negative	--	9253	470
08-10-09	Kitchen	Positive	Negative	--	9254	470
08-10-09	Lower Women's RR	Positive	Negative	--	9255	470

**ACTION REQUIRED:**

- Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Mail or other direct delivery to each customer;
  - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;



Mr. Max Fetterman  
August 19, 2009  
Page 2

- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.
  4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to collect four (4) additional routine samples in August 2009. You are also required to collect five (5) reoutine samples in September 2009.

If you have any questions, contact this office at 419-373-3007.

Sincerely,



Robert A. Plotts  
Division of Drinking and Ground Waters

/llr

Enclosures: Tier 2 Public Notification (2)  
Public Notice Instructions and Verification Form

pc: Henry County Health Department  
Information Management Section, DDAGW, CO  
DDAGW - NWDO (w/enclosures)